

One disadvantage of these types of speed control is a potential lack of environmental qualification data in accordance with IEEE 323,<sup>73</sup> and quality assurance programs in accordance with 10 CFR 50, Appendix B,<sup>51</sup> which are required for safety-related equipment. However, for non-nuclear-safety-related applications, these requirements do not apply and speed control is a possible option to consider.

### 5.6.3 PRESSURE CONTROL

Effluent air cleaning systems are typically controlled to vary the system flow rate to maintain building (or space) pressure. This is accomplished by maintaining constant supply airflow and varying exhaust flow by adjusting control dampers and inlet vanes, and through speed control similar to the techniques described in Section 5.6.2. Accurately sensing building pressure and outside air pressure is important for achieving a stable operating system. The sensing system should incorporate a "dead leg" to dampen the system reaction to wind gusts. Multiple outdoor and, if necessary, indoor sensors should be provided to obtain an average outside air pressure. To maintain a building at a negative pressure with respect to the lowest outside air pressure, the outdoor sensors should be located on each exposure. The system should then be designed to control flow based on the highest positive pressure sensed (the one that would result in the most infiltration).

Sensors should be located with due consideration given to local pressure fluctuations, eddy currents, and the turbulence that can be experienced at building corners and roof edges. Chapter 14 of the *ASHRAE Handbook of Fundamentals* provides guidance on determining turbulent zones due to airflow around buildings. This information must be considered in locating the sensors.

### 5.6.4 QUALIFICATION AND TESTING

All instruments used in ESF nuclear safety air cleaning systems must be qualified for environmental and seismic conditions in accordance with ASME AG-1, Section IA,<sup>63</sup> IEEE 323,<sup>73</sup> and IEEE 344.<sup>76</sup>

All instruments and devices must be calibrated and tested in accordance with manufacturer's test

procedures. In addition, all power wiring internal to control panels, except control or shielded cable, should be subjected to a high-potential test to demonstrate freedom from ground and correct wiring connections.

It is recommended that extensive onsite pre-operational testing be performed on all instrumentation and control systems associated with nuclear air cleaning systems prior to placing the systems in service. Pre-operational testing should be performed to confirm correct installation and design and to ensure correct operability of the control system and operated equipment. USNRC Regulatory Guides 1.68<sup>77</sup> and 1.68.3<sup>78</sup> provide guidance on what should be considered in pre-operational tests.

## 5.7 Other Considerations

### 5.7.1 Security

Ductwork, openings for intakes and exhaust stacks, and other types of building penetrations and pathways must be properly protected against security threats. Security measures for these openings and pathways are addressed in the facility security requirements.

### 5.7.2 ENERGY CONSERVATION

Specialized products and components for energy conservation may be appropriately used for the facility HVAC systems. In employing these components, care must be exercised to avoid using products that cannot be decontaminated or would otherwise limit the ability of the air cleaning systems to perform their design basis functions.

## 5.8 REFERENCES

1. *ASHRAE* (American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc., ), *2000 Systems and Equipment Handbook s*, Chap. 2, "Building Air Distribution," and Chap. 16, "Duct Construction," Atlanta, GA., 2000.

2. ASHRAE (American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc.) *Fundamentals Handbook*, Atlanta, GA, 2001.
3. American Conference of Governmental Industrial Hygienists, *Industrial Ventilation- A Manual of Recommended Practice*, 23<sup>rd</sup> Ed, Cincinnati, OH. 1998.
4. ANSI (American National Standards Institute,) *Fundamentals Governing the Design and Operation of Local Exhaust Systems*, ANSI Z9.2, New York, 1971. Sheet Metal and Air Conditioning Contractors' National Association (SMACNA), *HVAC Systems - Duct Design*, 3rd Edition, Chantilly, VA., 1990.
5. U.S. Nuclear Regulatory Commission (USNRC), *Design, Inspection, and Testing Criteria for Air Filtration and Adsorption Units of Post Accident Engineered-Safety-Feature Atmosphere Cleanup Systems in Light-Water-Cooled Nuclear Power Plants*, Regulatory Guide 1.52, Revision 3, Washington, DC, 2001.
6. U.S. Nuclear Regulatory Commission, *Design, Inspection, and Testing Criteria for Air Filtration and Adsorption Units of Normal Atmosphere Cleanup Systems in Light-Water-Cooled Nuclear Power Plants*, Regulatory Guide 1.140, Revision 2, Washington, DC, 2001.
7. Morton, M.R. (Letter to editor). *Inst. Heating and Ventilating Eng.* 37, A-5 (March 1970).
8. Stratton, John, personal communication to C. A. Burchsted., Director of Research, Sheet Metal and Air Conditioning Contractors' National Association.
9. ASTM (American Society for Testing and Materials), , *Standard Specification for Flexible Cellular Material- Sponge or Expanded Rubber s*, ASTM D1056-00, West Conshohocken, PA,, 2000.
10. ASME (American Society of Mechanical Engineers) *Power Piping*, American ASME B31.1, New York, NY, 2001.
11. ASME (American Society of Mechanical Engineers), *Boiler and Pressure Vessel Code*, New York, NY2001.
12. Stevens, R. E., personal communication to C. A. Burchsted, National Fire Protection Association.
13. First, M. W., Harvard Air Cleaning Laboratory, personal communication to C. A. Burchsted, Harvard University.
14. ANSI (American National Standards Institute, \_ *Protective Coatings (Paints),for the Nuclear Industry*, ANSI N512,,New York, 1974.
15. Carrier Corp., *System Design Manual*, Part 1, "Loading Estimating," *System Design Manual*, Part 1, York, Pa., 1960, pp.1-110 and 1-111.
16. ASME (American Society of Mechanical Engineers), *Testing of Nuclear Air Cleaning Systems*, ASME N510, New York. 1989 (R 1995).
17. Monsanto Research Corp., in which C. A. Burchsted served as consultant, Unreported tests at Mound Laboratory..
18. Stratton, John, personal communication to C. A. Burchsted., Director of Research and Development, Sheet Metal and Air Conditioning Contractors' National Association,
19. AMCA (Air Moving and Conditioning Association) *Laboratory Methods for Testing Dampers. For Rating AMCA 500-D*,, Arlington Heights, Ill., 1998.
20. AMCA (Air Moving and Conditioning Association,, "Fans and Systems," Part 2 of the *Fan Application Manual*, Publication 201, Arlington Heights, Il., 1990.
21. AMCA (Air Moving and Conditioning Association)"Field Performance Measurements Guide for Fans," Part 4 of the *Fan Application Manual*, Publication 203, Arlington Heights, Il., 1990.
22. American Conference of Governmental Industrial Hygienists., *Industrial Ventilation--A Manual of Recommended Practice*,
23. Air Diffusion Council (ADC)
24. American Institute of Steel Construction (AISC)26.American Iron and Steel Institute (AISI)
25. AMCA (Air Movement and Control Association), *Laboratory Methods for Testing*

- Louvers for Rating, AMCA 500-L, Arlington Heights, Ill., 1999.
26. American National Standards Institute (ANSI)
  27. American Nuclear Society (ANS)
  28. American Society of Heating and Air Conditioning Engineers (ASHRAE)
  29. American Society of Mechanical Engineers (ASME)
  30. American Society of Nondestructive Testing
  31. American Society of Testing and Materials
  32. American Welding Society (AWS)
  33. 310 CFR, Part 50, "*Domestic Licensing of Production and Utilization Facilities*," U.S. Nuclear Regulatory Commission.
  34. Institute of Electrical and Electronics Engineers (IEEE)
  35. National Society of Corrosion Engineers (NACE)
  36. National Electrical Manufacturers Association (NEMA)
  37. Nuclear Construction Issues Group (NCIG)
  38. Sheet Metal and Air Conditioning Contractors National Association, Inc. (SMACNA)
  39. Steel Structures Painting Council (SSPC)
  40. U.S. Government Printing Office
  41. ASHRAE Handbook of Fundamentals, Chapter 33, 1985.
  42. ASME (American Society of Mechanical Engineers) 2000 AddendCode on Nuclear Air and Gas Treatment, ASME AG-1, New York, NY, 2000.
  43. AMCA (Air Moving and Control Association,) Laboratory Methods of Testing Fans for Aerodynamic Performance Rating, AMCA 210, Arlington Heights, IL, 1999.
  44. ASHRAE Handbook, Chapter 14
  45. Pullman Sheet Metal Works, Ruskin Tests
  46. ANS Single Failure Criteria
  47. NEMA (National Electrical Manufacturers Association,), "Enclosures for Electrical Equipment (1000 Volts Maximum)", NEMA-250-1997 Rosslyn, VA, 1997.
  48. UL (Underwriters Laboratories) , "Fire Dampers", Underwriters Laboratories, Northbrook, IL, UL 555, 6<sup>th</sup> Edition, 1999 (Scope revised 2002).
  49. UL (Underwriters Laboratories) "Smoke Dampers UL 555S, 4<sup>th</sup> Edition, Northbrook, IL, 1999 (Scope revised 2002).
  50. Buffalo Forge Company, Fan Engineering , 8<sup>th</sup> Edition, Buffalo, NY, 1983.
  51. American Society of Heating, Ventilating, and Air-Conditioning Engineers , ASHRAE Duct Fitting Database (3.5" Diskette), Atlanta, GA, 1994.
  52. IEEE (Institute of Electrical and Electronic Engineers), *Standard for Qualifying Class IE Equipment for Nuclear Power Generating Stations*, IEEE 323, New York, NY, 1983.
  53. ANSI/IEEE (American National Standards Institute/Institute of Electrical and Electronic Engineers), *Radiation Protection Instrumentation Test and Calibration, Portable Survey Instruments*, ANSI/IEEE N323A, New York, NY, 1997.
  54. IEEE (Institute of Electrical and Electronic Engineers ), *Standard Test Procedure for Polyphase Induction Motors and Generators*, IEEE 112-96, New York, NY, 1996
  55. U.S. Nuclear Regulatory *Initial Test Programs for Water-Cooled Nuclear Power Plants*, R.G. 1.168, Revision 2, , D.C., 1978.
  56. U.S. Nuclear Regulatory Commission, *Proportional Testing of Instrument ant and Control Air Systems*, R.G. 1.168-3 Washington, D.C,
  57. IEEE (Institute of Electrical and Electronic Engineers), *IEEE Standard for Installation, Inspection, and Testing Requirements for Power, Instrumentation, and Control Equipment at Nuclear Facilities*,"IEEE 336, 1985.
  58. IEEE (Institute of Electrical and Electronic Engineers), *IEEE Standard for Type Test of Class IE Electric Cables, Field Splices, and Connections*, IEEE 383, 1974.
  59. IEEE (Institute of Electrical and Electronic Engineers), *Standard Criteria for Independence of Class IE Equipment and Circuits*,"for Type Test

of Class IE Electric Cables, Field Splices, and Connections,” IEEE 384.

60. *ASHRAE* (American Society of Heating, Refrigerating, and Air Conditioning Engineers), 1999 *Applications Handbook*, Chapter 11, “Industrial Air Conditioning” and Chapter 25, “Nuclear Facilities” Atlanta, GA, 1999.
61. 10 CFR, Part 100, “Reactor Site Criteria,” U.S. Nuclear Regulatory Commission.
62. U.S. Nuclear Regulatory Commission (USNRC), *Spray Pond Piping Made from Fiberglass-Reinforced Thermosetting Resin*, Regulatory Guide 1.72, Washington, DC.

*This Page Intentionally Blank*